

## Introduction

Bulletin 105 required dP switches to be installed on all filter monitor vessels used for into-plane fuelling purposes and the dP switch activation to be reset at 15 psi (1.0 bar).

JIG1 3.1.4 (c) requires that the dP switch shall not be capable of being reset by the fuelling operator or neutralised by the deadman override. The system shall be fitted with a reset mechanism that is appropriately controlled by authorised personnel, e.g. a key operated device.

JIG has been made aware of instances where the dP switch reset key was not being properly controlled, for example the reset key was available to operators rather than controlled by supervisors. In addition, JIG is aware of instances where the dP switch activation can be reset by a simple restart of the fuelling vehicle.

It is important to emphasise that the requirements of JIG1 3.1.4 (c) shall be applied to the control of the dP switch resetting in all cases. The system shall not be capable of being reset by the fuelling operator and it shall be installed so that the deadman override or restart of the vehicle does not reset and reactivate the system.

The action required by this bulletin is a one-off verification of the control and operation of dP switch resetting.

## Actions to Implement this Bulletin (See Table 1 for Action Type Codes)

Action Description	Action Type	Target Completion Date
<u>One off verification</u> Confirm that all dP switches fitted to all filter vessels are: <ul style="list-style-type: none"><li>- Only capable of being reset by authorised personnel (i.e. the use of the reset key is controlled by authorised personnel)</li><li>- Not capable of being reset by deadman override or a vehicle restart, otherwise appropriate rectification shall be planned</li></ul>	RP	31 <sup>st</sup> July 2018

**Table 1 Action Type Codes**

Action Types	JIG Bulletin Action Type Definition
JS	Change to JIG Standard – to be adopted by JV and/or Operator to continue to meet the JIG Standard(s) (JIG 1, 2, 4, EI/JIG 1530 and the JIG HSSE Management System).
RP	JIG Recommended Practice which the JV should consider adopting as its own practice (**).
I	Issued for information purposes only.
Note (**) - If the JV agreements require any of the JIG Standards and/or any of the JIG Common Processes as the governing operational standard then adoption of changes to applicable JIG Standards and/or Common Processes should not be considered optional by the JV Board.	

**Note:** This document is intended for the guidance of Members of JIG and companies affiliated with Members of JIG, and does not preclude the use of any other operating procedures, equipment or inspection procedures. The information contained in this publication is subject to constant review in the light of changing government requirements and regulations. Although efforts are made to keep this information up-to-date, accurate, complete, and free from error, we make no representation, warranty or guarantee, whether express or implied, that the information is up-to-date, accurate, complete, free from error, or in compliance with applicable law and regulations. No subscriber or other reader should act on the basis of any such information without referring to applicable laws and regulations and/or without taking appropriate professional advice. None of JIG, its Members, the Companies affiliated with its Members accepts responsibility for any loss or damage, whether in contract, tort (including negligence), breach of statutory duty, or otherwise, even if foreseeable, arising under or in connection with your use, adoption or reliance on the information in this document. You use this information at your own risk, but for the full terms and conditions concerning use of this document, please refer to <http://www.jigonline.com/legal-and-copyright/>

JIG is the owner of the copyright and all intellectual property rights in the publication.

IATA uses such rights with permission from JIG.